



2X Stud Framing to be designed by Architect or Engineer of Record based on wind loads and the cladding being used.




NOTE:
1. Steel reinforcement is required for window sizes > 36" x 60" or for a Negative Design Pressure > 30 psf.

11-1/4" (TYP.) for two (2) locks (req'd for widths > 24")
(One lock req'd @ CL for widths <= 24")



FRAME ANCHORING
2X Framing shown



1 HORIZONTAL CROSS SECTION
2 2X Framing



2 HORIZONTAL CROSS SECTION
2 2X Framing



3 VERTICAL CROSS SECTION
2 2X Framing



Documents Prepared By: Lyndon F. Schmidt, P.E.
TEXAS P.E. #104123
RW BUILDING CONSULTANTS, INC.
P.O. Box 230 Valrico FL 33595
Phone No.: 813.659.9197
TEXAS BOARD OF PROFESSIONAL ENGINEERS
CERTIFICATE OF REGISTRATION # F-11852

PRODUCT:		Single Hung Window	
PART OR ASSEMBLY:		FRAME ANCHORING & CROSS SECTIONS	
NO.		DATE	
BY		REVISIONS	
DATE: 10/27/14			
SCALE: N.T.S.			
DWG. BY: JK			
CHK. BY: LFS			
DRAWING NO.: TX-4444			
SHEET 2 OF 3			

